

Yuba Community College District

RFP No. 25-08

Yuba College, Irrigation Tank Replacement Project

ADDENDUM NO. 2

Tuesday, July 9, 2025

District: Yuba Community College District

District Offices

3301 E Onstott Rd

Yuba City, CA 95991

Contact: David Willis, Dir. Facilities Planning, Maintenance & Operations

Job Location: Yuba Community College

Building 600 (south side)

2088 N Beale Rd

Marysville, CA 95901

Clarifications:

- 1. Question:** Since the new irrigation tank is not exactly a straight across replacement tank and is a higher pressure rating, and since the foundation supports need to meet seismic and other California code requirements, will this project design be submitted to the Division of the State Architect's Office (DSA)?

Answer: Yes, the District has decided that this project now needs to be submitted to DSA. The District will be hiring a DSA Inspector of Record and a Structural Inspections and Testing Firm. The Contractor will need to design the new tank and structural supports and submit the drawings and calculations to DSA for review and approval. This will require that a licensed engineer or Architect sign and submit the design package to DSA. The California Licensed Architect or Engineer will need to also support the construction process and if required, prepare any required additional documents to DSA such as Construction Change Directives (CCD's) to DSA for approval. The Contractor shall include all associated costs for this work in the proposal.

End of Addendum No.2